

2022 WATER QUALITY REPORT

for the

CITY OF McCALLSBURG

The city of McCallsburg strives to provide you with a safe, dependable supply of drinking water that is in compliance with the guidelines established by the Environmental Protection Agency (EPA). This report contains important information regarding the water quality of McCallsburg's water system. The city of McCallsburg purchases its water through a bulk connection with Iowa Regional Utilities Association (IRUA). The Marshalltown Water Works supplies the water to IRUA, which is pumped from nine deep wells located on the north side of the Iowa River drawing from the Buried Sand and Gravel and Pleistocene Aquifers. Our water quality testing shows the following results:

Contaminant	MCL (MCLG)	Compliance		Year Tested	Violation	Source
		Type	Result (Range)			
City of McCallsburg Distribution System						
Lead (ppb)	AL=15 (0)	90 th	0.60 (ND-1)	2021	No	Corrosion of household plumbing systems; Erosion of natural deposits.
Copper (ppm)	AL=1.3 (1.3)	90 th	0.0062 (ND – 0.0062)	2021	No	Corrosion of plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.
Distribution System						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	2.2 (1.58 – 2.6)	2022	No	Water additive used to control microbes.
Nitrite [as N] (ppm)	1 (1)	SGL	0.180	2022	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Water Supplied to IRUA by Marshalltown Water Works						
Fluoride (ppm)	4 (4)	SGL	0.7	2022	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories.
Sodium (ppm)	N/A (N/A)	SGL	16	2022	No	Erosion of natural deposits; Added to water during the treatment process.

The EPA requires monitoring of over 80 drinking water contaminants. Those listed above are the only contaminants detected in your drinking water. Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb – parts per billion
- ppm – parts per million
- pCi/L – picocuries per liter
- N/A – Not applicable
- ND – Not detected
- RAA – Running Annual Average
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- SGL – Single Sample Result
- RTCR – Revised Total Coliform Rule
- NTU – Nephelometric Turbidity Units

GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of McCallsburg is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater/lead>.

SOURCE WATER ASSESSMENT INFORMATION

Iowa Regional Utilities Association purchases the water it provides McCallsburg from Marshalltown Water Works. Marshalltown Water Works obtains its source water from the Buried Sand and Gravel and Pleistocene aquifers. The Buried Sand and Gravel and Pleistocene aquifers were determined to have low susceptibility to contamination because the characteristics of the aquifer and overlying materials provide natural protection from contaminants at the land surface. The Buried Sand and Gravel wells will have low susceptibility to surface contaminants such as leaking underground storage tanks, contaminant spills, and excess fertilizer application. A detailed evaluation of your source water was completed by the IDNR, and is available from Iowa Regional Utilities Association at (641) 792-7011.

OTHER INFORMATION

The City of McCallsburg is making every effort to protect the water system from potential security threats. You, as customers, can also help. If you see any suspicious activity near any part of the water system, please contact us at (515) 434-2242 or the local police/sheriff department. We appreciate your assistance in protecting the water system.

For questions regarding this information, please contact Rhonda Guy, Water Operator, at (515) 434-2242. Decisions regarding the water system are made at the McCallsburg City Council meetings, which are held on the second and fourth Mondays at 7:00 p.m. at the McCallsburg City Hall; 425 Main St.; McCallsburg, Iowa and are open to the public.